

City of Taunton - Cost Estimation for Parking Facilities

**City Priorities**  
 Priority 1: Program Access  
 Priority 2: Safety  
 Priority 3: Approach and Entrance  
 Priority 4: Access to Goods and Services  
 Priority 5: Toilet or Bathing Rooms  
 Priority 6: Additional Access

**\*Cost Estimate Notes:**  
 - Cost of design is not included  
 - Does not include costs when note indicates future work  
 - Labor cannot be estimated for all remedies  
 - There is no cost noted when it's presumed to be a maintenance issue.  
 Estimates are intended as a guide to budgeting access modifications and are not intended to be absolutely comprehensive or definitive.

| Information Provided by Institute for Human Centered Design |                      |                 |                              |  |                               |               |                              |   |                                   | Information Provided by City of Taunton |                         |                                 |                 |   |
|---|----------------------|-----------------|------------------------------|--|-------------------------------|---------------|------------------------------|---|-----------------------------------|---|-------------------------|---------------------------------|-----------------|---|
| FACILITY  | REFERENCE #          | FD WORK ORDER # | ELEMENT                      | ISSUE / PHYSICAL BARRIER   | LOCATION WITHIN FACILITY      | CITY PRIORITY | PRIORITY FOR BARRIER REMOVAL | ACTION FOR BARRIER REMOVAL  | ESTIMATED COST OF BARRIER REMOVAL | PROJECT START DATE                      | PROJECT COMPLETION DATE | RESPONSIBLE FOR BARRIER REMOVAL | BARRIER REMOVED | X |
| Court St.   | No assigned record # |                 | C. Accessible Route/Walkway  | H. Cross slope >1:48<br>G. Running slope >1:20   |                               | Priority 3    | Approach and Entrance        | Correct the cross and run slopes adjoining the curb ramp.   |                                   | 2017                                    |                         | Parking Commission              |                 |   |
| Court Street Parking Lot                                    | 8B-060, P-001        |                 | B. Curb Ramp                 | A. Running slope at curb ramp > 1:12<br>B. Cross slope >1:48   |                               | Priority 3    | Approach and Entrance        | Correct slope and cross slope at curb ramp.   | \$116.25                          | 2017                                    |                         | Parking Commission              |                 |   |
| Bay Street Parking Lot                                      | P-002                |                 | D. Off-Street Parking Spaces | A. Total # of parking spaces<br>B. Total # of designated accessible spaces<br>C. Minimum number of spaces not provided<br>D. Van space not provided<br>N. Not in operable working condition                            | parking lot                   | Priority 1    | Program Access               | Provide one van-accessible space. Provide an access aisle. Provide parking identification sign.                                   | \$870.00                          | 2017                                    |                         | Parking Commission              |                 |   |
| Galligan's Court Parking Lot                                | P-003                |                 | D. Off-Street Parking Spaces | A. Total # of parking spaces<br>B. Total # of designated accessible spaces<br>D. Van space not provided<br>M. Sign <60" above finished floor   | Weir Street entrance          | Priority 3    | Approach and Entrance        | Provide one van-accessible space. Provide marking at access aisle. Provide parking identification signs.                          | \$870.00                          | 2017                                    |                         | Parking Commission              |                 |   |
| Galligan's Court Parking Lot                                | P-004                |                 | D. Off-Street Parking Spaces | A. Total # of parking spaces<br>B. Total # of designated accessible spaces<br>J. Surface not stable, firm, and slip-resistant<br>M. Sign <60" above finished floor   | entrance near Lincoln Street  | Priority 3    | Approach and Entrance        | Provide one van-accessible space. Provide marking at access aisle. Provide parking identification sign.                           | \$870.00                          | 2017                                    |                         | Parking Commission              |                 |   |
| Galligan's Court Parking Lot                                | 8B-0062              |                 | C. Accessible Route/Walkway  | H. Cross slope >1:48   | entrance near Lincoln Street  | Priority 3    | Approach and Entrance        | Correct cross slope at accessible route.  |                                   | 2017                                    |                         | Parking Commission              |                 |   |
| Parking Deck  | P-008                |                 | B. Curb Ramp                 | A. Running slope at curb ramp > 1:12   | near southeast stairwell      | Priority 1    | Program Access               | Correct slope at curb ramp.   | \$116.25                          | 2016                                    | May-16                  | Parking Commission              | completed       |   |
| Parking Deck  | P-005                |                 | D. Off-Street Parking Spaces | A. Total # of parking spaces<br>B. Total # of designated accessible spaces<br>D. Van space not provided  | near southwest stairwell      | Priority 1    | Program Access               | Provide 2 accessible parking spaces. Provide one van-designated space. Provide parking identification sign.                       | \$874.50                          | 2016                                    | May-16                  | Parking Commission              | completed       |   |
| Parking Deck  | P-006                |                 | D. Off-Street Parking Spaces | A. Total # of parking spaces<br>B. Total # of designated accessible spaces<br>D. Van space not provided  | near southwest stairwell      | Priority 1    | Program Access               | Provide 2 accessible parking spaces. Provide one van-designated space. Provide parking identification sign.                       | \$874.50                          | 2016                                    | May-16                  | Parking Commission              | completed       |   |
| Parking Deck  | P-007                |                 | D. Off-Street Parking Spaces | A. Total # of parking spaces<br>B. Total # of designated accessible spaces<br>D. Van space not provided<br>F. Vehicle space <96" wide, access aisle <60" wide, access aisle does not adjoin accessible route           | near southwest stairwell      | Priority 1    | Program Access               | Provide 2 accessible parking spaces. Provide one van-designated space. Provide parking identification sign.                       | \$874.50                          | 2016                                    | May-16                  | Parking Commission              | completed       |   |
| Parking Deck  | P-009                |                 | D. Off-Street Parking Spaces | A. Total # of parking spaces<br>B. Total # of designated accessible spaces<br>D. Van space not provided<br>J. Surface not stable, firm, and slip-resistant<br>M. Sign <60" above finished floor                        | near building entrance        | Priority 1    | Program Access               | Provide 2 accessible parking spaces. Provide one van-designated space. Provide parking identification sign.                       | \$1,740.00                        | 2016                                    | May-16                  | Parking Commission              | completed       |   |
| Parking Deck  | 8B-063               |                 | G. Stairway (in a Walkway)   | F. Handrails not continuous where required<br>J. Handrails do not extend 12" from stairs   |                               | Priority 1    | Program Access               | Provide handrail extensions on both sides of stairway   | \$280.00                          | 2016                                    | May-16                  | Parking Commission              | completed       |   |
| Trescott Street Parking Lot                                 | P-010                |                 | D. Off-Street Parking Spaces | A. Total # of parking spaces<br>B. Total # of designated accessible spaces<br>C. Minimum number of spaces not provided<br>D. Van space not provided<br>M. Sign <60" above finished floor                               | entrance near Trescott Street | Priority 3    | Approach and Entrance        | Regrade and restripe parking lot. Provide one van-designated space. Provide an access aisle. Provide parking identification sign. | \$1,270.00                        | 2017                                    |                         | Parking Commission              |                 |   |
| Trescott Street Parking Lot                                 | P-011                |                 | D. Off-Street Parking Spaces | A. Total # of parking spaces<br>B. Total # of designated accessible spaces<br>C. Minimum number of spaces not provided<br>D. Van space not provided<br>M. Sign <60" above finished floor                               | entrance near Cedar Street    | Priority 3    | Approach and Entrance        | Provide an access aisle. Provide parking identification sign.   | \$1,500.00                        | 2017                                    |                         | Parking Commission              |                 |   |
| Trescott Street Parking Lot                                 | 8B-064               |                 | D. Off-Street Parking Spaces | M. Sign <60" above finished floor  | entrance nr Main St.          | Priority 3    | Approach and Entrance        | Provide parking identification sign.  | \$262.00                          | 2017                                    |                         | Parking Commission              |                 |   |
| Weir Street Parking Lot                                     | P-012                |                 | D. Off-Street Parking Spaces | M. Sign <60" above finished floor<br>A. Total # of parking spaces<br>B. Total # of designated accessible spaces<br>C. Minimum number of spaces not provided<br>D. Van space not provided<br>F. Vehicle space <96" wide | entrance near W Water Street  | Priority 3    | Approach and Entrance        | Provide one van-accessible space. Provide an access aisle.  | \$870.00                          | 2017                                    |                         | Parking Commission              |                 |   |
|   |                      |                 |                              |  |                               |               |                              |   | <b>\$11,388.00</b>                |   |                         |                                 |                 |   |